

BACnet Errata
Addendum *j* to ANSI/ASHRAE STANDARD 135-2008
A Data Communication Protocol for Building Automation and Control Networks

February 10, 2010

This document lists all known *errata* to Addendum *j* to ANSI/ASHRAE 135-2008 as of the above date. Each entry is cited first by clause, then page number, except where an erratum covers more than one clause. **The changes that should be made are shown below (*italic* for added text, ~~strikeout~~ for deleted).**

1) In the change to ANNEX C, p.72 of the addendum, the Reliability property is incorrectly marked as OPTIONAL. Correct the ASN.1 as follows:

[Add new object type structure to **ANNEX C**, p. 497]

```
CREDENTIAL-DATA-INPUT ::= SEQUENCE {  
    ...  
    reliability          [103] BACnetReliability-OPTIONAL,
```