

**ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15-2013,
Safety Standard for Refrigeration Systems**

March 6, 2015

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 15-2013. The outside back cover marking identifying the first printing is “Product code: 86021 11/13”. The shaded items have been added since the previous errata sheet dated January 5, 2015 was published.

Page Erratum

8 **7.3.2.2 Plenums.** Revise Section 7.3.2.2 as shown below.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

7.3.2.2 Plenums. The space above a suspended ceiling shall not be included in calculating the refrigerant concentration ~~quantity~~-limit in the system unless such space is part of the air supply or return system.

8 **7.3.2.3 Supply and Return Ducts.** Revise Section 7.3.2.3 as shown below.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

7.3.2.3 Supply and Return Ducts. The volume of the supply and return ducts and plenums shall be included when calculating the refrigerant concentration ~~quantity~~-limit in the system.

12 **9.3.1.1.** Add the word “or” immediately following Section 9.3.1.1a as shown below.
(Note: Additions are shown in underline.)

9.3.1.1 Pressure vessels having inside dimensions of 6 in. (152 mm) or less shall be

- a. listed either individually or as part of an assembly by an approved, nationally recognized testing laboratory, or

14 **9.7.5.** In Section 9.7.5 the definition of the variable L in the equation $C = fDL$ was inadvertently left out of the first printing of the 2013 edition. Add the following definition after the definition for variable D and before the definition of variable f .

L = length of vessel, ft (m)