

**ERRATA SHEET FOR ANSI/ASHRAE/ASHE Addendum m to
ANSI/ASHRAE/ASHE STANDARD 170-2017
Ventilation of Health Care Facilities**

February 7, 2023

The corrections listed in this errata sheet apply to ANSI/ASHRAE/ASHE Addendum m to ANSI/ASHRAE/ASHE Standard 170-2017. The first printing of Addendum m is identified on the outside back cover as “7/20”. Shaded items have been added since the previously published errata sheet dated November 15, 2021 was distributed.

Page Erratum

- | | |
|----------|--|
| 3 | Table 7-1 Design Parameters—Inpatient Spaces. In Table 7-1 for Seclusion room in Behavioral and Mental Health Facilities change Minimum Outdoor ach to 2 and Minimum Total ach to 4 as shown in the attached. Changes highlighted in yellow.
<i>(Note: Additions are shown in <u>underline</u> and deletions are shown in strikethrough.)</i> |
| 3 | Table 8.1 Design Parameters – Outpatient Spaces (Continued). For Sterilizer equipment room change the Air Recirculated by Means of Room Units listed in Table 8.1 from “No” to “NR” as shown in the attached. Changes highlighted in yellow.
<i>(Note: Additions are shown in <u>underline</u> and deletions are shown in strikethrough.)</i> |

Table 7-1 Design Parameters – Inpatient Spaces (Continued)

Function of Space (ee)	Pressure Relationship to Adjacent Areas (n)	Minimum Outdoor ach	Minimum Total ach	All Room Air Exhausted Directly to Outdoors (j)	Air Recirculated by Means of Room Units (a)	Unoccupied Turndown	Minimum Filter Efficiencies (cc)	Design Relative Humidity (k), %	Design Temperature (l), °F/°C
BEHAVIORAL AND MENTAL HEALTH FACILITIES (k)									
Seclusion room (FGI 2.1–2.4.3 & 2.2–2.12.4.3)	NR	42	24	NR	NR	Yes	MERV-8	NR	NR

Revise Table 8.1 as shown below. The remainder of Table 8.1 is unchanged.

Function of Space (f)	Pressure Relationship to Adjacent Areas (n)	Minimum Outdoor ach	Minimum Total ach	All Room Air Exhausted Directly to Outdoors (j)	Air Recirculated by Means of Room Units (a)	Minimum Filter Efficiencies (c)	Design Relative Humidity (k), %	Design Temperature (l), °F/°C
STERILE PROCESSING (aa)								
Sterilizer equipment room (FGI 2.1-4.3.2.2)	Negative	NR	10	Yes	NR-Ne	MERV-8	NR	NR