

ERRATA SHEET FOR ANSI/ASHRAE/ACCA STANDARD 180-2018
Standard Practice for Inspection and Maintenance of
Commercial Building HVAC Systems

October 3, 2023

The corrections listed in this errata sheet apply to ANSI/ASHRAE/ACCA Standard 180-2018. The first printing is identified on the outside back cover a “Product code: 86533 6/18”.

<u>Page</u>	<u>Erratum</u>
-------------	----------------

5	4.3.2.2 Inspection and Maintenance Task Frequencies. Revise Section 4.3.2.2 as shown below. <i>(Note: Additions are shown in <u>underline</u> and deletions are shown in striketrough.)</i>
----------	--

4.3.2.2 Inspection and Maintenance Task Frequencies.

The baseline frequencies of inspection and *maintenance tasks* for *equipment* and systems are listed in the tables in Section 5. These frequencies are the minimum required for compliance.

Refer to Section ~~4.5~~ 4.6 for requirements for revising inspection and *maintenance task* frequencies.

[...]