

**ERRATA SHEET FOR  
ANSI/ASHRAE STANDARD 33-2016  
Methods of Testing Forced-Circulation Air-Cooling and Air-Heating Coils**

**May 4, 2020**

The corrections listed in this errata sheet apply to the first printing of ANSI/ASHRAE Standard 33-2016 identified on the outside back cover as “Product code: 86083 4/16”. The shaded items have been added since the previously published errata sheet dated July 22, 2016 was distributed.

**Page                      Erratum**

**4**                      **Section 5 Symbols.** In the symbols for SG,  $W$  and  $\Delta W$  change the units from “kg dry water (lb dry water)” to “kg dry air (lb dry air)” as shown below.  
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

SG = specific gravity, as in correcting for relative density of air-water vapor mixture =

$$\frac{1 + W}{1 + \frac{W}{0.622}}$$

(dry air SG = 1.00), kg air-water vapor mixture/(kg dry airwater) [lb air-water vapor mixture/(lb dry airwater)]

$W$  = humidity ratio of air-water vapor mixture, kg water vapor mixture/(kg dry airwater) [lb water vapor mixture/(lb dry airwater)]

$\Delta W$  = difference in air humidity ratio across dehumidifying coil, kg water vapor mixture/(kg dry airwater) [lb water vapor mixture/(lb dry airwater)]

**15**                      **In Section 11.1.2.** The equations are missing the term  $(1-\beta^4)$  in the denominator and should read as follows:

$$w_a = \frac{6.556}{10^5} C_N (D_N)^2 E \cdot \phi \left( \frac{\Delta p_N P_{N1}}{T_{N1db} (1-\beta^4) (1+W_{N1}) \left(1 + \frac{W_{N1}}{0.622}\right)} \right)^{0.5}, \text{ kg dry air/s}$$

$$[w_a = 6.888 C_N (D_N)^2 E \cdot \phi \left( \frac{\Delta p_N \cdot P_{N1}}{T_{N1db} (1-\beta^4) (1+W_{N1}) \left(1 + \frac{W_{N1}}{0.622}\right)} \right)^{0.5}, \text{ lbm dry air/min}]$$

**TD-33\_Steam\_**      The formula for SG<sub>m</sub> - Average air specific gravity in Data Number {48}  
**SI**                      incorrectly divided the entire numerator by 0.622 and should read:

$$\frac{1 + \{47\}}{1 + \frac{\{47\}}{0.622}}$$

**TD-33\_Steam**  
**\_SI**

The formula for Nozzle factor formula in Data Number {26} has been updated to reflect the correction for average air specific gravity and should read:

$$E\phi \left( \frac{\{13\}(\{5\} + \{14\})}{\{25\}(1 - \beta^4)(1 + \{24\}) \left(1 + \frac{\{24\}}{0.622}\right)} \right)^{0.5}$$

**TD-33\_Steam**  
**\_I-P**

The formula for SG<sub>m</sub> - Average air specific gravity in Data Number {48} incorrectly divided the entire numerator by 0.622 and should read:

$$\frac{1 + \{47\}}{1 + \frac{\{47\}}{0.622}}$$

**TD-33\_Steam**  
**\_I-P**

The formula for Nozzle factor formula in Data Number {26} has been updated to reflect the correction for average air specific gravity and should read:

$$E\phi \left( \frac{\{13\}(\{5\} + \{14\})}{\{25\}(1 - \beta^4)(1 + \{24\}) \left(1 + \frac{\{24\}}{0.622}\right)} \right)^{0.5}$$

**TD-33\_DX\_I-P**

The formula for SG<sub>m</sub> - Average air specific gravity in Data Number {114} incorrectly divided the entire numerator by 0.622 and should read:

$$\frac{1 + \{113\}}{1 + \frac{\{113\}}{0.622}}$$

**TD-33\_DX\_I-P**

The formula for Nozzle factor formula in Data Number {49} has been updated to reflect the correction for average air specific gravity and should read:

$$E\phi \left( \frac{\{13\}(\{5\} + \{14\})}{\{48\}(1 - \beta^4)(1 + \{47\}) \left(1 + \frac{\{47\}}{0.622}\right)} \right)^{0.5}$$

**TD-33\_DX\_SI**

The formula for SG<sub>m</sub> - Average air specific gravity in Data Number {114} incorrectly divided the entire numerator by 0.622 and should read:

$$\frac{1 + \{113\}}{1 + \frac{\{113\}}{0.622}}$$

**TD-33\_DX\_SI**

The formula for Nozzle factor formula in Data Number {49} has been updated to reflect the correction for average air specific gravity and should read:

$$E\phi \left( \frac{\{13\}(\{5\} + \{14\})}{\{48\}(1 - \beta^4)(1 + \{47\}) \left(1 + \frac{\{47\}}{0.622}\right)} \right)^{0.5}$$

**TD-33\_Single-Phase-SI**

The formula for  $SG_m$  - Average air specific gravity in Data Number {60} incorrectly divided the entire numerator by 0.622 and should read:

$$\frac{1 + \{59\}}{1 + \frac{\{59\}}{0.622}}$$

**TD-33\_Single-Phase-SI**

The formula for Nozzle factor formula in Data Number {32} has been updated to reflect the correction for average air specific gravity and to correct equation references and should read:

$$E\phi \left( \frac{\{13\}(\{5\} + \{14\})}{\{31\}(1 - \beta^4)(1 + \{30\}) \left(1 + \frac{\{30\}}{0.622}\right)} \right)^{0.5}$$

**TD-33\_Single-Phase-I-P**

The formula for  $SG_m$  - Average air specific gravity in Data Number {60} incorrectly divided the entire numerator by 0.622 and should read:

$$\frac{1 + \{59\}}{1 + \frac{\{59\}}{0.622}}$$

**TD-33\_Single-Phase-I-P**

The formula for Nozzle factor formula in Data Number {32} has been updated to reflect the correction for average air specific gravity and to correct equation references and should read:

$$E\phi \left( \frac{\{13\}(\{5\} + \{14\})}{\{31\}(1 - \beta^4)(1 + \{30\}) \left(1 + \frac{\{30\}}{0.622}\right)} \right)^{0.5}$$