

**ERRATA SHEET FOR
ANSI/ASHRAE STANDARD 90.4-2016
Energy Standard for Data Centers**

May 31, 2018

The corrections listed in this errata sheet apply to all copies of ANSI/ASHRAE Standard 90.4-2016. The first printing is identified on the outside back cover as “Product code: 86277 7/16”.

<u>Page</u>	<u>Erratum</u>
13	Table 8.2.1.2 <i>Maximum Design Electrical Loss Component (Design ELC) and ELC Segments Systems (IT Design Load ≤ 100 kW)</i>^a. Change the IT Design Load in the title of Table 8.2.1.2 from “≤ 100 kW” to “≥ 100 kW”.